

SITE Northern Hospital of Surrey county-B

REVIEW DATES 6/19/97

~~REGUST~~

NONREG

NONUST (circle)

REVIEWER

Tkm

☒ UST-12 FORMAT (closures 2/1/95 and after)

☒ VOLUME OF UST (tnk1 5000 tnk2 _____ tnk3 _____ tnk4 _____)

☒ DIMENSIONS OF UST (tnk1 8' x 13.5' tnk2 _____ tnk3 _____ tnk4 _____)

☒ MATERIAL STORED (tnk1 diethyl fuel tnk2 _____ tnk3 _____ tnk4 _____)

☒ POTENTIAL RECEPTOR INFORMATION (closures 2/1/95 or after)

☒ DEPTH OF TANK BURIAL 1' BLS

☒ SIDE OR FLOOR SAMPLE

☒ DEPTH OF SAMPLE 2'

☒ HOW SAMPLE WAS COLLECTED (____ backhoe ☒ Auger ____ Grab)

☒ SAMPLES PRESERVED & TRANSPORTED

☒ SSE ACCEPTABLE

☒ ANALYSIS METHOD 5030 / 3550

☒ SEALED BY IG or PE (Needed for closures 1/1/94 - 7/1/96. After 7/1/96 a PG or PE is required only for sites that have a release or suspected release).

NAME/# OF SEALER Joseph R. Best 11451

CONSULTING COMPANY Fair Seasons

☒ USGS MAP

☒ BASE MAP ☒ Orientation of UST ☒ APPROPRIATE SAMPLE LOCATIONS

☒ REFERENCE TO SAMPLING POINT ON MAP ☒ CORRECT # OF TANK SAMPLES

☒ PUMP SAMPLES

☒ LINE SAMPLES NONREG

☒ COMPLETE GW/UST-2 FORM (1/1/91 and after) NONREG

☒ CLOSURE DATE

☒ TANK DESTINATION fair seasons

☒ SLUDGE DESTINATION " "

☒ DISPOSITION OF SOIL

☒ TIME/DATE SAMPLE COLLECTED

☒ TIME/DATE LAB RECEIVED

☒ CHAIN-OF-CUSTODY

☒ WITHIN 14 DAY HOLDING TIME (or appropriate time)

☒ LAB RESULTS

☒ CERTIFIED LABORATORY USED (closures 8/1/93 and after)

☒ Minor Soil _____ Major Soil _____ GW Violations

Comments:

Clean closure